



# AGA CERTIFIED PRODUCT



Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **008 134 512**

Manufacturer: **AUSTRALIAN PIPELINE VALVE**

Agent (if applicable): **N/A**

Type of Component: **Manual Ball Valve**

Model No. & Description: **APV  
SLFSBVO1 (150LB & 300LB) Series**

**Nominal sizes (mm)**  
**150LB Series – 15, 20, 25, 32, 40, 50, 65, 80 & 100**  
**300LB Series – 15, 20, 25, 40, 50, 65, 80 & 100**  
**Operating temperature range: 0-100°C**  
**Rated maximum working pressure:**  
**300LB series: 5100 kPa @ 38°C**  
**150LB series: 1965 kPa @ 38°C**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)*

Relevant Standard(s): **AS 4617 – 2004  
(Incorporating Amendment 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



*John Vanderz*

**Client Manager**

*[Signature]*

**Certificate Authorised**

Certificate first issued: **11 November 2014**

Certificate No: **8137**

This copy valid from: **8 March 2017**

Refer specification issue: **03**

# Directory Certificate Entry

## Components

### Manual Shut-Off Valves

#### Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2004 Amdt 1 | Manual Shut-Off Gas Valves | 9/03/2011

#### APV (AUSTRALIAN PIPELINE VALVE)

8137 11.14

##### Manual Ball Valves

SLFSBVO1 (150lb & 300lb) SERIES:

Nominal sizes (mm)

SLFSBVO1 (150LB) Series:

15, 20, 25, 32, 40, 50, 65, 80, 100

SLFSBVO1 (300LB) Series:

15, 20, 25, 40, 50, 65, 80, 100

kPa Rating

1965 @ 38°C

5100 @ 38°C

Operating Temperature Range: 0°C to 100°C

Thursday, 9 March 2017

# AGA CERTIFIED PRODUCT



Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **008 134 512**

Manufacturer: **AUSTRALIAN PIPELINE VALVE**

Agent (if applicable): **N/A**

Type of Component: **Manual Ball Valve**

Model No. & Description: **APV**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)* **BV100 SERIES BALL VALVES**  
**CLASS 800 FULL BORE**  
**Pressure rating: 13800kPa**  
**Temperature rating: 0 to 100°C**  
**Seat material: RPTFE**  
**Nominal sizes: DN15, DN20 & DN25**  
**End connections: Threaded NPT or BSP,**  
**Socket weld (SW), Butt weld (BW)**

Relevant Standard(s): **AS 4617 – 2004**  
**(Incorporating Amendment 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



*John Vanderzoo*

**Client Manager**

*[Signature]*

**Certificate Authorised**

Certificate first issued: **21 April 2017**

Certificate No: **8327**

This copy valid from: **21 April 2017**

Refer specification issue: **01**

# Directory Certificate Entry

## Components

### Manual Shut-Off Valves

#### Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2004 Amdt 2 | Manual shut off gas valves | 21/12/2016

#### APV

8327 4.17

#### *BV100 Series Ball Valves*

CLASS 800 FULL BORE

Temperature rating: 0 to 100°C

Seat material: RPTFE

Nominal sizes: DN15, DN20 & DN25

End connections: Threaded NPT or BSP, Socket weld (SW), Butt weld (BW)

#### *kPa Rating*

13800

Monday, 24 April 2017