



AGA CERTIFIED PRODUCT



Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **008 134 512**

Manufacturer: **AUSTRALIAN PIPELINE VALVE**

Agent (if applicable): **N/A**

Type of Component: **Manual Ball Valve**

Model No. & Description: **APV
SLFSBVO1 (150LB & 300LB) Series**

Nominal sizes (mm)
150LB Series – 15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150 & 200
300LB Series – 15, 20, 25, 40, 50, 65, 80, 100, 150 & 200
Operating temperature range: 0-100°C
Rated maximum working pressure:
300LB series: 5100 kPa @ 38°C
150LB series: 1965 kPa @ 38°C
(Refer www.aga.asn.au for more details)

Relevant Standard(s): **AS 4617 – 2018**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



John Vanderz

Client Manager

[Signature]

Certificate Authorised

Certificate first issued: **11 November 2014**

Certificate No: **8137**

This copy valid from: **12 December 2019**

Refer specification issue: **04**

Directory Certificate Entry

Components

Manual Shut-Off Valves

Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2018 | Manually operated gas valves | 28/06/2018

APV (AUSTRALIAN PIPELINE VALVE)

8137 11.14

Manual Ball Valves

kPa Rating

SLFSBVO1 (150LB & 300LB) SERIES:

Nominal sizes (mm)

SLFSBVO1 (150LB) Series:

15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150 & 200

1965 @ 38°C

SLFSBVO1 (300LB) Series:

15, 20, 25, 40, 50, 65, 80, 100, 150 & 200

5100 @ 38°C

Operating Temperature Range: 0°C to 100°C

Friday, 13 December 2019

AGA CERTIFIED PRODUCT



www.jas-anz.org/register

Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **008 134 512**

Manufacturer: **AUSTRALIAN PIPELINE VALVE**

Agent (if applicable): **N/A**

Type of Component: **Manual Ball Valve**

Model No. & Description: **APV**
(Refer www.aga.asn.au for more details) **BV100 SERIES BALL VALVES**
CLASS 800 FULL BORE
Pressure rating: 13800kPa
Temperature rating: 0 to 100°C
Seat material: RPTFE
Nominal sizes: DN15, DN20, DN25, DN32, DN40 & DN50
End connections: Threaded NPT or BSP, Socket weld (SW), Butt weld (BW)


Relevant Standard(s): **AS 4617 – 2004**
(Incorporating Amendment 1 & 2)

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.





Client Manager



Certificate Authorised

Certificate first issued: **21 April 2017**

Certificate No: **8327**

This copy valid from: **19 December 2017**

Refer specification issue: **02**

QF714/11

Directory Certificate Entry

Components

Manual Shut-Off Valves

Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2004 Amdt 2 | Manual shut off gas valves | 21/12/2016

APV

8327 4.17

BV100 Series Ball Valves

CLASS 800 FULL BORE

Temperature rating: 0 to 100°C

Seat material: RPTFE

Nominal sizes: DN15, DN20, DN25, DN32, DN40 & DN50

End connections: Threaded NPT or BSP, Socket weld (SW), Butt weld (BW)

kPa Rating

13800

Tuesday, 19 December 2017



AGA CERTIFIED PRODUCT

Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**
ABN/ACN No. (if applicable): **86 008 134 512**
Manufacturer: **Australian Pipeline Valve & Air Torque, Italy**
Agent (if applicable): **N/A**
Type of Component: **Automatic Shut-Off Valves**
Model No. & Description: **APV (AUSTRALIAN PIPELINE VALVE)**
(Refer www.aga.asn.au for more details) **SLFSBVO1 (150LB & 300LB) SERIES + AIR TORQUE ACTUATORS**

JAS-ANZ



www.jas-anz.org/register

Nominal sizes (mm):

150LB Series – 15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150 & 200

300LB Series – 15, 20, 25, 40, 50, 65, 80, 100, 150 & 200

Operating temperature range: 0°C to 100°C

Rated maximum working pressure: 300LB series: 5100 kPa @ 38°C

150LB series: 1965 kPa @ 38°C

Actuator componentry:

Air Torque actuators,

ASCO 551, 314 OR 327 Series or BURKERT 6518 OR 6519 Series solenoids,

I-tork ITS series Limit Switches, configured to meet proof of closure, and

end user control/position monitoring requirements, and;

Numatics SEV or ASCO MV27 Series Quick Exhaust valves (optional if required)

(Assemblies may be optionally fitted with an Air Filter Regulator at client's request)


Relevant Standard(s): **AS4629-2005 (Incorporating Amendment No 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.





Client Manager



Certificate Authorised

Certificate first issued: **26 May 2021**

Certificate No: **8971**

This copy valid from: **26 May 2021**

Refer specification issue: **01**

Directory Certificate Entry

Components

Automatic Shut Off Valves

Class I

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s: [AS 4629](#) | [2005 Amdt 2](#) | [Automatic shut off valves and vent valves](#) | 21/12/2016

APV (AUSTRALIAN PIPELINE VALVE)

8971	5.21	Nominal Size mm	Connections In	Designation	Rated kPa	Oper Posn
				SLFSBV01 (150LB & 300LB) SERIES + AIR TORQUE ACTUATORS		
				150LB Series		See notes
				Nominal sizes(mm) 15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150 & 200		
				Operating Temperature Range: 0°C to 100°C		
				Rated Maximum Working Pressure: 1965kPa @ 38°C		
				300LB Series		See notes
				Nominal sizes(mm) 15, 20, 25, 40, 50, 65, 80, 100, 150 & 200		
				Operating Temperature Range: 0°C to 100°C		
				Rated Maximum Working Pressure: 5100 kPa @ 38°C		

Notes:

Actuator componentry:

Air Torque actuators,

ASCO 551, 314 OR 327 Series or BURKERT 6518 OR 6519 Series solenoids,

I-tork ITS series Limit Switches, configured to meet proof of closure, and end user control/position monitoring requirements, and;

Numatics SEV or ASCO MV27 Series Quick Exhaust valves (optional if required)

(Assemblies may be optionally fitted with an Air Filter Regulator at client's request)

Monday, 31 May 2021