



# AGA CERTIFIED PRODUCT



Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **008 134 512**

Manufacturer: **AUSTRALIAN PIPELINE VALVE**

Agent (if applicable): **N/A**

Type of Component: **Manual Ball Valve**

Model No. & Description: **APV  
SLFSBVO1 (150LB & 300LB) Series**

**Nominal sizes (mm)**  
**150LB Series – 15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150 & 200**  
**300LB Series – 15, 20, 25, 40, 50, 65, 80, 100, 150 & 200**  
**Operating temperature range: 0-100°C**  
**Rated maximum working pressure:**  
**300LB series: 5100 kPa @ 38°C**  
**150LB series: 1965 kPa @ 38°C**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)*

Relevant Standard(s): **AS 4617 – 2018**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



*John Vanderz*

**Client Manager**

*[Signature]*  
**Certificate Authorised**

Certificate first issued: **11 November 2014**

Certificate No: **8137**

This copy valid from: **12 December 2019**

Refer specification issue: **04**

# Directory Certificate Entry

## Components

### Manual Shut-Off Valves

#### Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2018 | Manually operated gas valves | 28/06/2018

#### APV (AUSTRALIAN PIPELINE VALVE)

8137 11.14

##### Manual Ball Valves

##### kPa Rating

SLFSBVO1 (150LB & 300LB) SERIES:

Nominal sizes (mm)

SLFSBVO1 (150LB) Series:

15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150 & 200

1965 @ 38°C

SLFSBVO1 (300LB) Series:

15, 20, 25, 40, 50, 65, 80, 100, 150 & 200

5100 @ 38°C

Operating Temperature Range: 0°C to 100°C

Friday, 13 December 2019

# AGA CERTIFIED PRODUCT



Certificate Holder: **GLOBAL SUPPLY LINE PTY LTD**

ABN/ACN No. (if applicable): **008 134 512**

Manufacturer: **AUSTRALIAN PIPELINE VALVE**

Agent (if applicable): **N/A**

Type of Component: **Manual Ball Valve**

Model No. & Description: **APV  
BV100 SERIES BALL VALVES  
CLASS 800 FULL BORE  
Pressure rating: 13800kPa  
Temperature rating: 0 to 100°C  
Seat material: RPTFE  
Nominal sizes: DN15, DN20, DN25, DN32,  
DN40 & DN50  
End connections: Threaded NPT or BSP,  
Socket weld (SW), Butt weld (BW)**

(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)

Relevant Standard(s): **AS 4617 – 2004  
(Incorporating Amendment 1 & 2)**


This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



**Client Manager**



**Certificate Authorised**



Certificate first issued: **21 April 2017**

Certificate No:

**8327**

This copy valid from: **19 December 2017**

Refer specification Issue:

**02**

# Directory Certificate Entry

## Components

### Manual Shut-Off Valves

#### Type 1 - Isolating Valves

Global Supply Line Pty Ltd

(1-23 Barndioota Road, Salisbury Plain, 5109 SA AUSTRALIA Ph: 08 8285 0016)

Relevant Standard/s:

AS 4617 | 2004 Amdt 2 | Manual shut off gas valves | 21/12/2016

## APV

8327

4.17

### BV100 Series Ball Valves

CLASS 800 FULL BORE

Temperature rating: 0 to 100°C

Seat material: RPTFE

Nominal sizes: DN15, DN20, DN25, DN32, DN40 & DN50

End connections: Threaded NPT or BSP, Socket weld (SW), Butt weld (BW)

### kPa Rating

13800

Tuesday, 19 December 2017